**TALIWORKS ANALYTICAL LABORATORY SDN. BHD. (207862-H)**

38, JALAN SS 21/35, DAMANSARA UTAMA, 47400 PETALING JAYA
SELANGOR DARUL EHSAN, MALAYSIA.

Tel: 603-7727 0246, 7727 2667 Fax: 603-7729 2798

**CERTIFICATE OF ANALYSIS**

Opinion and interpretation expressed herein are outside the scope of SAMM accreditation * This report shall not be reproduced except in full and with prior approval of Taliworks Analytical Laboratory Sdn. Bhd.

YOUR P.O.NO. : 4524/21
OUR REF. : TAL/ECTSB/5/2021
REGISTRATION NO. : TAL/0472/2021
ACCOUNTS NO. : TAL 423
COMPANY : **ECOCLEAN TECHNOLOGY SDN.BHD.**
12A-18, Wisma Zelan,
Jalan Tasik Permaisuri 2,
Bandar Tun Razak, Cheras,
56000 Kuala Lumpur.


ATTENTION
DESCRIPTION OF SAMPLE : **Mr. Lee Teck Ngu**
SAMPLING POINT : Water Sample
SAMPLING DATE & TIME : Tiong Nam Outlet
DATE RECEIVED : 2nd November 2021
DATE ISSUED : 2nd November 2021
DATE RECEIVED : 10th November 2021

On analysis of the sample(s) submitted, the following results were obtained :

PHYSICAL & CHEMICAL ANALYSIS REPORT

NO.	PARAMETER	UNIT	METHOD REF. NO.: APHA-	RESULTS
1	pH (In situ)	-	4500-H ⁺ B	8.1 @ 29.6°C
2	TOTAL SUSPENDED SOLIDS	mg/L	2540 D	<2
3	DISSOLVED OXYGEN (In situ)	mg/L	4500-O G	7.6
4	TEMPERATURE (In situ)	°C	2550 B	29.7
5	BIOCHEMICAL OXYGEN DEMAND @ 20 °C For 5 Days	mg/L	5210 B & 4500-O G	<0.6
6	CHEMICAL OXYGEN DEMAND	mg/L	5220 B	6
7	AMMONIA as N	mg/L	4500-NH ₃ B & F	0.07
8	OIL & GREASE	mg/L	5520 B	<0.2
9	E. COLI** @ 35 °C For 24 Hours	CFU/ 100ml	9222 B	3





TALIWORKS ANALYTICAL LABORATORY SDN. BHD. (207862-H)

38, JALAN SS 21/35, DAMANSARA UTAMA, 47400 PETALING JAYA

SELANGOR DARUL EHSAN, MALAYSIA.

Tel: 603-7727 0246, 7727 2667 Fax: 603-7729 2798



CERTIFICATE OF ANALYSIS

Opinion and interpretation expressed herein are outside the scope of SAMM accreditation * This report shall not be reproduced except in full and with prior approval of Taliworks Analytical Laboratory Sdn. Bhd.

ECOCLEAN TECHNOLOGY SDN.BHD.

(ECTSB5/2021)

NOTE:

- 1 "<" denotes "less than"
- 2 "***" denotes "The Parameter is Not SAMM Accredited and do not come under the scope of SAMM Accreditation."
- 3 The sample(s) (as received) is properly stored in the sampling container.
- 4 All the laboratory analysis is performed from 2/11/2021 to 10/11/2021.
- 5 Biochemical Oxygen Demand analysis started on: 3rd November 2021.
- 6 This Test Report is prepare based on the tests requested and on the specific sample(s) as received for analysis.

METHOD REFERENCE

Standard Methods for the Examination of Water and WasteWater (2005) 21st Edition, APHA,AWWA,WEF.

TAN SIEW SIEW
HEAD OF LABORATORY
(SAMM APPROVED SIGNATORY)
IKM NO.: M/2546/4372/03/07