

**TALIWORKS ANALYTICAL LABORATORY SDN. BHD.** (207862-H)

38, JALAN SS 21/35, DAMANSARA UTAMA, 47400 PETALING JAYA

SELANGOR DARUL EHSAN, MALAYSIA.

Tel: 603-7727 0246, 7727 2667, 7727 6057 Fax: 603-7726 6872, 7729 2798

MS ISO/IEC 17025
TESTING
SAMM NO. 033**CERTIFICATE OF ANALYSIS**

Opinion and interpretation expressed herein are outside the scope of SAMM accreditation * This report shall not be reproduced except in full and with prior approval of Taliworks Analytical Laboratory Sdn. Bhd.

OUR REF. : TAL/ECTSB/3-A/2013
REGISTRATION NO. : TAL/0516-A/2013
ACCOUNT NO. : TAL 423
COMPANY : ECOCLEAN TECHNOLOGY SDN.BHD.
12A-02, 03 & 03A, Wisma Zelan,
Jalan Tasik Permaisuri 2,
Bandar Tun Razak, Cheras,
56000 Kuala Lumpur.

ATTENTION
DESCRIPTION OF SAMPLE : Mr. Lee Teck Ngu
SAMPLING DATE : Water Sample
DATE RECEIVED : 27th August 2013
DATE ISSUED : 27th August 2013
DATE ISSUED : 6th September 2013

On analysis of the sample(s) submitted, the following results were obtained :

PHYSICAL & CHEMICAL ANALYSIS REPORT

NO.	PARAMETER	UNIT	METHOD REF. NO.: APHA-	RESULTS
				PILOT PLANT
1	pH	-	4500- H ⁺ B	4.7 @ 20.1°C
2	BIOCHEMICAL OXYGEN DEMAND @ 20 °C For 5 Days	mg/L	5210 B & 4500-O G	73.8
3	CHEMICAL OXYGEN DEMAND	mg/L	5220 B	168
4	TOTAL SUSPENDED SOLIDS	mg/L	2540 D	100
5	AMMONIA as N	mg/L	4500-NH ₃ B & F	2.46
6	PHOSPHORUS as PO ₄ (TOTAL)	mg/L	4500 P D	11.35
7	OIL & GREASE	mg/L	5520 B	0.2

NOTE:

- 1 " NA " denotes " not analysed "
- 2 Biochemical Oxygen Demand analysis started on : 29th August 2013

METHOD REFERENCE

- 1 Standard Methods for the Examination of Water and WasteWater (2005) 21st Edition, APHA, AWWA, WEF.

TAN SIEW SIEW
HEAD OF LABORATORY (A.M.I.C)
IKM NO.: A/2546/4372/03/07