



TALIWORKS ANALYTICAL LABORATORY SDN. BHD. (207862-H)
38, JALAN SS 21/35, DAMANSARA UTAMA, 47400 PETALING JAYA
SELANGOR DARUL EHSAN, MALAYSIA.
Tel: 603-7727 0246, 7727 2667, 7727 6057 Fax: 603-7726 6872, 7729 2798



MS ISO/IEC 17025
TESTING
SAMM NO. 033

CERTIFICATE OF ANALYSIS

Opinion and interpretation expressed herein are outside the scope of SAMM accreditation* This report shall not be reproduced except in full and with prior approval of Taliworks Analytical Laboratory Sdn. Bhd.

OUR REF. : TAL/ECTSB/4/2013
REGISTRATION NO. : TAL/0541/2013
ACCOUNT NO. : TAL 423
COMPANY : ECOCLEAN TECHNOLOGY SDN.BHD.
12A-02, 03 & 03A, Wisma Zelan,
Jalan Tasik Permaisuri 2,
Bandar Tun Razak, Cheras,
56000 Kuala Lumpur.

ATTENTION : Mr. Lee Teck Ngu
SOURCE : Pilot Plant
DESCRIPTION OF SAMPLE : Water Sample
SAMPLING POINT : (1) Inlet
(2) Outlet

SAMPLING DATE : 6th September 2013
DATE RECEIVED : 6th September 2013
DATE ISSUED : 17th September 2013

On analysis of the sample(s) submitted, the following results were obtained :

PHYSICAL & CHEMICAL ANALYSIS REPORT

NO.	PARAMETER	UNIT	METHOD REF. NO.: APHA-	RESULTS	
				(1) Inlet	(2) Outlet
1	BIOCHEMICAL OXYGEN DEMAND @ 20 °C For 5 Days	mg/L	5210 B & 4500-O G	84.2	12.6
2	TOTAL SUSPENDED SOLIDS	mg/L	2540 D	99	11
3	NITROGEN (ORGANIC) as N	mg/L	4500-N _{org} B	1.38	0.50
4	OIL & GREASE	mg/L	5520 B	<0.1	<0.1

NOTE:

- 1 "<" denotes "less than"
- 2 Biochemical Oxygen Demand analysis started on : 6th September 2013

METHOD REFERENCE

- 1 Standard Methods for the Examination of Water and WasteWater (2005) 21st Edition, APHA, AWWA, WEF.

TAN SIEW SIEW
HEAD OF LABORATORY (A.M.I.C)
IKM NO.: A/2546/4372/03/07