



CERTIFICATE OF ANALYSIS

Opinion and interpretation expressed herein are outside the scope of SMM accreditation* This report shall not be reproduced except in full and with prior approval of Taliworks Analytical Laboratory Sdn. Bhd.

OUR REF. : TAL/ECTSB/4/2013
REGISTRATION NO. : TAL/0541/2013
ACCOUNT NO. : TAL 423
COMPANY : ECOCLEAN TECHNOLOGY SDN.BHD.
12A-02, 03 & 03A, Wisma Zelan,
Jalan Tasik Permaisuri 2,
Bandar Tun Razak, Cheras,
56000 Kuala Lumpur.
ATTENTION : Mr. Lee Teck Ngu
SOURCE : Pilot Plant
DESCRIPTION OF SAMPLE : Water Sample
SAMPLING POINT : (1) Inlet
(2) Outlet
SAMPLING DATE : 6th September 2013
DATE RECEIVED : 6th September 2013
DATE ISSUED : 17th September 2013

On analysis of the sample(s) submitted, the following results were obtained :

PHYSICAL & CHEMICAL ANALYSIS REPORT

| NO. | PARAMETER | UNIT | METHOD REF. NO.: APHA- | RESULTS | |
|-----|---|------|------------------------------|--------------|---------------|
| | | | | (1) Inlet | (2) Outlet |
| 1 | BIOCHEMICAL OXYGEN DEMAND @ 20 °C For 5 Days | mg/L | 5210 B & 4500-O G | 84.2 | 12.6 |
| 2 | TOTAL SUSPENDED SOLIDS | mg/L | 2540 D | 99 | 11 |
| 3 | NITROGEN (ORGANIC) as N | mg/L | 4500-N _{org} B | 1.38 | 0.50 |
| 4 | OIL & GREASE | mg/L | 5520 B | <0.1 | <0.1 |

NOTE:

- "<" denotes "less than"
- Biochemical Oxygen Demand analysis started on : 6th September 2013

METHOD REFERENCE

- Standard Methods for the Examination of Water and WasteWater (2005) 21st Edition, APHA, AWWA, WEF.

TAN SIEW SIEW
HEAD OF LABORATORY (A.M.I.C)
IKM NO.: A/2546/4372/03/07